





# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：家興人力資源顧問股份有限公司  
 行業別：自述業別  
 採樣地點：香山富群二館 3F-B 飲水機  
 (新竹市香山區 )  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2444  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月05日14時05分  
 收樣時間：113年06月06日  
 報告日期：113年06月21日  
 報告編號：C1132444-2

樣品報告編號		C1130606J				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月06日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：家興人力資源顧問股份有限公司  
 行業別：自述業別  
 採樣地點：香山富群二館 4F-A 飲水機  
 (新竹市香山區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2444  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月05日14時10分  
 收樣時間：113年06月06日  
 報告日期：113年06月21日  
 報告編號：C1132444-3

樣品報告編號		C1130606K				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月06日 12時00分	LES Endo Agar	1倍/0.0	NIEA E230.55B	6	
以下空白								

PASS



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：家興人力資源顧問股份有限公司  
 行業別：自述業別  
 採樣地點：香山富群二館 4F-B 飲水機  
 (新竹市香山區)

委託編號：YZ1131C2444  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月05日14時15分  
 收樣時間：113年06月06日

採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

報告日期：113年06月21日  
 報告編號：C1132444-4

樣品報告編號		C1130606L				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月06日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS





## 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
受檢單位：家興人力資源顧問股份有限公司  
行業別：自述業別  
採樣地點：香山富群二館 5F-B 飲水機  
(新竹市香山區)

委託編號：YZ1131C2444  
樣品基質：飲用水  
檢測目的：定檢  
採樣時間：113年06月05日14時25分  
收樣時間：113年06月06日

採樣單位：御安淨水企業有限公司  
採樣方法：---  
採樣行程代碼：---

報告日期：113年06月21日  
報告編號：C1132444-6

樣品報告編號		C1130606N				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月06日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

**Environmental Technology Research Center**  
**YUAN ZE UNIVERSITY**  
**Analysis Report**

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Xiangshan Fuqun Building 2 ,1F Water Dispenser  
**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Client Number:** YZ1131C2444  
**Sample Base:** Drinking Water  
**Test purpose:** **Regular inspection**  
**Sampling Date:** 06/05/2024 14:00  
**Sample Received:** 06/06/2024  
**Report Date:** 06/21/2024  
**Report Number:** C1132444-1

Sample Report Number		C1130606I				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/06/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								
<b>PASS</b>								



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

**Environmental Technology Research Center**  
**YUAN ZE UNIVERSITY**  
**Analysis Report**

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Xiangshan Fuqun Building 2, 3F-B Water Dispenser  
**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Client Number:** YZ1131C2444  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/05/2024 14:05  
**Sample Received:** 06/06/2024  
**Report Date:** 06/21/2024  
**Report Number:** C1132444-2

Sample Report Number		C1130606J				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/06/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**





Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

**Environmental Technology Research Center**  
**YUAN ZE UNIVERSITY**  
**Analysis Report**

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Xiangshan Fuqun Building 2, 4F-A Water Dispenser  
**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Client Number:** YZ1131C2444  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/05/2024 14:10  
**Sample Received:** 06/06/2024  
**Report Date:** 06/21/2024  
**Report Number:** C1132444-3

Sample Report Number		C1130606K				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/06/2024 12:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
<b>The END</b>								
			<b>PASS</b>					



Accreditation number by NERA : 041  
(original Accreditation number by EPA : 041)

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan  
County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Xiangshan Fuqun Building 2, 4F-B Water Dispenser  
**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Client Number:** YZ1131C2444  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/05/2024 14:15  
**Sample Received:** 06/06/2024  
**Report Date:** 06/21/2024  
**Report Number:** C1132444-4

Sample Report Number		C1130606L				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/06/2024 12:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
<b>The END</b>								
<b>PASS</b>								



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Xiangshan Fuqun Building 2, 5F-A Water Dispenser  
**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Client Number:** YZ1131C2444  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/05/2024 14:20  
**Sample Received:** 06/06/2024  
**Report Date:** 06/21/2024  
**Report Number:** C1132444-5

Sample Report Number		C1130606M				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/06/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**



Accreditation number by NERA : 041  
(original Accreditation number by EPA : 041)

### Environmental Technology Research Center YUAN ZE UNIVERSITY Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Xiangshan Fuqun Building 2, 5F-B Water Dispenser  
**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Client Number:** YZ1131C2444  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/05/2024 14:25  
**Sample Received:** 06/06/2024  
**Report Date:** 06/21/2024  
**Report Number:** C1132444-6

Sample Report Number		C1130606N				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/06/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								
<b>PASS</b>								