



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B1/1F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時00分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-1

樣品報告編號		C11306260				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月26日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B2/2F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時05分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-2

樣品報告編號		C1130626P				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月26日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C2792
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：錄興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年06月25日16時10分
採樣地點：高雄長春一館 B3/3F 飲水機 (高雄市湖內區)	收樣時間：113年06月26日
採樣單位：御安淨水企業有限公司	報告日期：113年07月03日
採樣方法：---	報告編號：C1132792-3
採樣行程代碼：---	

樣品報告編號		C1130626Q				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月26日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								
		<b>PASS</b>						



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C2792
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：錄興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年06月25日16時15分
採樣地點：高雄長春一館 B4/4F 飲水機 (高雄市湖內區)	收樣時間：113年06月26日
採樣單位：御安淨水企業有限公司	報告日期：113年07月03日
採樣方法：---	報告編號：C1132792-4
採樣行程代碼：---	

樣品報告編號		C1130626R				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月26日 12時00分	LES Endo Agar	1倍/0.0	NIEA E230.55B	6	
以下空白								
<div style="border: 2px solid blue; padding: 10px; display: inline-block; font-size: 2em; font-weight: bold; color: blue;">PASS</div>								



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B5/5F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時20分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-5

樣品報告編號		C1130626S				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月26日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								
<b>PASS</b>								



## 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：鎩興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B6/6F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時25分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-6

樣品報告編號		C1130626T				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年06月26日 12時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								
			PASS					

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B1/1F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時00分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-7

樣品報告編號		C11306260				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年06月26日 12時00分	TGE Agar	1倍/0,0	NIEA E203.56B	100	
以下空白								

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C2792
委託者地址：桃園市平鎮區中豐路南勢二段127號	樣品基質：飲用水
受檢單位：錄興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年06月25日16時05分
採樣地點：高雄長春一館 B2/2F 飲水機 (高雄市湖內區)	收樣時間：113年06月26日
採樣單位：御安淨水企業有限公司	報告日期：113年07月03日
採樣方法：---	報告編號：C1132792-8
採樣行程代碼：---	

樣品報告編號		C1130626P				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年06月26日 12時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C2792
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：錄興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年06月25日16時10分
採樣地點：高雄長春一館 B3/3F 飲水機 (高雄市湖內區)	收樣時間：113年06月26日
採樣單位：御安淨水企業有限公司	報告日期：113年07月03日
採樣方法：---	報告編號：C1132792-9
採樣行程代碼：---	

樣品報告編號		C1130626Q				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年06月26日 12時00分	TGE Agar	1倍/0,0	NIEA E203.56B	100	
以下空白								

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B4/4F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時15分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-10

樣品報告編號		C1130626R				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年06月26日 12時00分	TGE Agar	1倍/0,0	NIEA E203.56B	100	
以下空白								

PASS

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司  
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號  
 受檢單位：錄興國際股份有限公司  
 行業別：自述業別  
 採樣地點：高雄長春一館 B5/5F 飲水機  
 (高雄市湖內區)  
 採樣單位：御安淨水企業有限公司  
 採樣方法：---  
 採樣行程代碼：---

委託編號：YZ1131C2792  
 樣品基質：飲用水  
 檢測目的：定檢  
 採樣時間：113年06月25日16時20分  
 收樣時間：113年06月26日  
 報告日期：113年07月03日  
 報告編號：C1132792-11

樣品報告編號		C1130626S				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年06月26日 12時00分	TGE Agar	1倍/0,0	NIEA E203.56B	100	
以下空白								

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1131C2792
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：錄興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：113年06月25日16時25分
採樣地點：高雄長春一館 B6/6F 飲水機 (高雄市湖內區 )	收樣時間：113年06月26日
採樣單位：御安淨水企業有限公司	報告日期：113年07月03日
採樣方法：---	報告編號：C1132792-12
採樣行程代碼：---	

樣品報告編號		C1130626T				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年06月26日 12時00分	TGE Agar	1倍/0,0	NIEA E203.56B	100	
以下空白								
								



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B1/ 1F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:00  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---  
**Report Date:** 07/03/2024  
**Report Number:** C1132792-1

Sample Report Number		C11306260				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/26/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B2/ 2F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:05  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-2

Sample Report Number		C1130626P				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/26/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								
		<b>PASS</b>						



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

**Environmental Technology Research Center  
 YUAN ZE UNIVERSITY**

**Analysis Report**

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan  
 County, Taiwan (R.O.C.)  
**Plant:** Golden –Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B3/ 3F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:10  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---  
**Report Date:** 07/03/2024  
**Report Number:** C1132792-3

Sample Report Number		C1130626Q				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/26/2024 12:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B4/ 4F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:15  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-4

Sample Report Number		C1130626R				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/26/2024 12:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**





Accreditation number by NERA : 041  
(original Accreditation number by EPA : 041)

**Environmental Technology Research Center  
YUAN ZE UNIVERSITY**

**Analysis Report**

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan  
County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B5/ 5F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:20  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-5

Sample Report Number		C1130626S				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/26/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY

Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B6/ 6F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:25  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-6

Sample Report Number		C1130626T				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	06/26/2024 12:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

**PASS**

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden –Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B1/ 1F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:00  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-7

Sample Report Number		C11306260				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking fountain						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	06/26/2024 12:00	TGE Agar	1/0 , 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden –Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B2/ 2F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:05  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-8

Sample Report Number		C1130626P				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking fountain						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	06/26/2024 12:00	TGE Agar	1/0 , 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B3/ 3F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:10  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-9

Sample Report Number		C1130626Q				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking fountain						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	06/26/2024 12:00	TGE Agar	1/0 , 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden –Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B4/ 4F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:15  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---  
**Report Date:** 07/03/2024  
**Report Number:** C1132792-10

Sample Report Number		C1130626R				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking fountain						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	06/26/2024 12:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B5/ 5F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:20  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-11

Sample Report Number		C1130626S				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking fountain						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	06/26/2024 12:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

PASS

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden –Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Kaohsiung Changchun 1st Building B6/ 6F Water Dispenser

**Client Number:** YZ1131C2792  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 06/25/2024 16:25  
**Sample Received:** 06/26/2024

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 07/03/2024  
**Report Number:** C1132792-12

Sample Report Number		C1130626T				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking fountain						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	06/26/2024 12:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
<b>The END</b>								

PASS