



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：永康四維館 32/1F 左邊飲水機
 (台南市永康區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4320
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年10月11日10時00分
 收樣時間：113年10月11日
 報告日期：113年10月17日
 報告編號：C1134320-1

樣品報告編號		C1131011D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年10月11日 18時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								



Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan
 County, Taiwan (R.O.C.)

Client Number: YZ1131C4320
Sample Base: Drinking Water

Plant: Golden Li H.R Consultant Co., Ltd

Test purpose: Regular inspection

IndustrialType: ---

Sampling Date: 10/11/2024 10:00

Sampling Site: Yongkang Sihwei dorm 32 / 1F water dispenser on the Left

Sample Received: 10/11/2024

Sampling Organization: Yuann International Technology Co., Ltd

Report Date: 10/17/2024

Sampling Method: ---

Report Number: C1134320-1

Sampling Code: ---

Sample Report Number		C1131011D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	10/11/2024 18:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								