



國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
行業別：自述業別 採樣時間：113年11月08日09時00分
採樣地點：高雄大學館 338 號 H01/10F 收樣時間：113年11月08日
(高雄市楠梓區大學七街 336、338 號)
採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
採樣方法：--- 報告編號：C1134898-1
採樣行程代碼：---

樣品報告編號		C1131108C				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								

PASS



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時05分
 採樣地點：高雄大學館 338 號 H02/4F 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-2
 採樣行程代碼：---

樣品報告編號		C1131108D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1 倍/0.0	NIEA E230.55B	6	
以下空白								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時10分
 採樣地點：高雄大學館 336 號 H03/4F 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-3
 採樣行程代碼：---

樣品報告編號		C1131108E				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								
PASS								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
委託者地址：桃園市平鎮區中豐路南勢二段 127 號
受檢單位：家興人力資源顧問股份有限公司
行業別：自述業別
採樣地點：高雄大學館 338 號 H04/1F
(高雄市楠梓區大學七街 336、338 號)
採樣單位：御安淨水企業有限公司
採樣方法：---
採樣行程代碼：---

委託編號：YZ1131C4898
樣品基質：飲用水
檢測目的：定檢
採樣時間：113年11月08日09時15分
收樣時間：113年11月08日
報告日期：113年11月19日
報告編號：C1134898-4

樣品報告編號		C1131108F				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時20分
 採樣地點：高雄大學館 338 號 H05/1F 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-5
 採樣行程代碼：---

樣品報告編號		C1131108G				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時25分
 採樣地點：高雄大學館 H06/B 棟 7F 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-6
 採樣行程代碼：---

樣品報告編號		C1131108H				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								
		PASS						



元智大學環科中心檢測實驗室 樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時30分
 採樣地點：高雄大學館 H07/A 棟 7F 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-7
 採樣行程代碼：---

樣品報告編號		C1131108I				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <p style="margin: 0;">以下空白</p> </div>								
<div style="border: 2px solid blue; padding: 10px; display: inline-block; font-size: 2em; font-weight: bold; color: blue;"> <p style="margin: 0;">PASS</p> </div>								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時35分
 採樣地點：高雄大學館 H08/A 棟 10F 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-8
 採樣行程代碼：---

樣品報告編號		C1131108J				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
委託者地址：桃園市平鎮區中豐路南勢二段 127 號
受檢單位：家興人力資源顧問股份有限公司
行業別：自述業別
採樣地點：高雄大學館 H09/1F 飲水機
(高雄市楠梓區大學七街 336、338 號)
採樣單位：御安淨水企業有限公司
採樣方法：---
採樣行程代碼：---

委託編號：YZ1131C4898
樣品基質：飲用水
檢測目的：定檢
採樣時間：113年11月08日09時40分
收樣時間：113年11月08日
報告日期：113年11月19日
報告編號：C1134898-9

樣品報告編號		C1131108K				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 H10/12F 飲水機
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時45分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-10

樣品報告編號		C1131108L				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								



國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：	御安淨水企業有限公司	委託編號：	YZ1131C4898
委託者地址：	桃園市平鎮區中豐路南勢二段 127 號	樣品基質：	飲用水
受檢單位：	家興人力資源顧問股份有限公司	檢測目的：	定檢
行業別：	自述業別	採樣時間：	113年11月08日09時50分
採樣地點：	高雄大學館 H11/12F 飲水機 (高雄市楠梓區大學七街 336、338 號)	收樣時間：	113年11月08日
採樣單位：	御安淨水企業有限公司	報告日期：	113年11月19日
採樣方法：	---	報告編號：	C1134898-11
採樣行程代碼：	---		

樣品報告編號		C1131108M				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	113年11月08日 19時00分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
<div style="border: 2px solid blue; padding: 10px; display: inline-block; font-size: 2em; font-weight: bold; color: blue;">PASS</div>								

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
委託者地址：桃園市平鎮區中豐路南勢二段127號
受檢單位：家興人力資源顧問股份有限公司
行業別：自述業別
採樣地點：高雄大學館338號H01/10F
(高雄市楠梓區大學七街336、338號)
採樣單位：御安淨水企業有限公司
採樣方法：---
採樣行程代碼：---

委託編號：YZ1131C4898
樣品基質：飲用水
檢測目的：定檢
採樣時間：113年11月08日09時00分
收樣時間：113年11月08日
報告日期：113年11月19日
報告編號：C1134898-12

樣品報告編號		C1131108C				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

PASS

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 338 號 H02/4F
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時05分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-13

樣品報告編號		C1131108D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

PASS

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 336 號 H03/4F
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時10分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-14

樣品報告編號		C1131108E				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 338 號 H04/1F
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時15分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-15

樣品報告編號		C1131108F				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0.0	NIEA E203.56B	100	
以下空白								

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 338 號 H05/1F
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時20分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-16

樣品報告編號		C1131108G				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
委託者地址：桃園市平鎮區中豐路南勢二段127號 樣品基質：飲用水
受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
行業別：自述業別 採樣時間：113年11月08日09時25分
採樣地點：高雄大學館H06/B棟7F 收樣時間：113年11月08日
(高雄市楠梓區大學七街336、338號)
採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
採樣方法：--- 報告編號：C1134898-17
採樣行程代碼：---

樣品報告編號		C1131108H				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段127號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 H07/A 棟 7F
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時30分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-18

樣品報告編號		C1131108I				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								
								

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 H08/A 棟 10F
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時35分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-19

樣品報告編號		C1131108J				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

PASS

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段127號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館H09/1F飲水機
 (高雄市楠梓區大學七街336、338號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時40分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-20

樣品報告編號		C1131108K				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0.0	NIEA E203.56B	100	
以下空白								

PASS

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司 委託編號：YZ1131C4898
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號 樣品基質：飲用水
 受檢單位：家興人力資源顧問股份有限公司 檢測目的：定檢
 行業別：自述業別 採樣時間：113年11月08日09時45分
 採樣地點：高雄大學館 H10/12F 飲水機 收樣時間：113年11月08日
 (高雄市楠梓區大學七街 336、338 號)
 採樣單位：御安淨水企業有限公司 報告日期：113年11月19日
 採樣方法：--- 報告編號：C1134898-21
 採樣行程代碼：---

樣品報告編號		C1131108L				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0.0	NIEA E203.56B	100	
以下空白								

PASS

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段127號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：高雄大學館 H11/12F 飲水機
 (高雄市楠梓區大學七街336、338號)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1131C4898
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：113年11月08日09時50分
 收樣時間：113年11月08日
 報告日期：113年11月19日
 報告編號：C1134898-22

樣品報告編號		C1131108M				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲水機						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
總菌落數	CFU/mL	<5	113年11月08日 19時00分	TGE Agar	1倍/0, 0	NIEA E203.56B	100	
以下空白								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H01/ 10F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:00
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-1

Sample Report Number		C1131108C				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								

PASS



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center YUAN ZE UNIVERSITY Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

Client Number: YZ1131C4898
Sample Base: Drinking Water

Plant: Golden Li H.R Consultant Co., Ltd
Industrial Type: ---

Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:05

Sampling Site: Kaohsiung University dormitory No.338 H02/ 4F
(No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Sample Received: 11/08/2024

Sampling Organization: Yuann International Technology Co., Ltd

Report Date: 11/19/2024

Sampling Method: ---

Report Number: C1134898-2

Sampling Code: ---

Sample Report Number		C1131108D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.336 H03/ 4F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:10
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-3

Sample Report Number		C1131108E				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H04/ 1F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:15
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-4

Sample Report Number		C1131108F				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H05/ 1F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:20
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-5

Sample Report Number		C1131108G				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H06/ Building B 7F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:25
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-6

Sample Report Number		C1131108H				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
		PASS						



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H07 /Building A 7F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:30
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-7

Sample Report Number		C1131108I				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H08 /Building A 10F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:35
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-8

Sample Report Number		C1131108J				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H09/ 1F water dispenser (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:40
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-9

Sample Report Number		C1131108K				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd

Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

Plant: Golden Li H.R Consultant Co., Ltd

IndustrialType: ---

Sampling Site: Kaohsiung University dormitory H10/ 12F water dispenser (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Sampling Organization: Yuann International Technology Co., Ltd

Sampling Method: ---

Sampling Code: ---

Client Number: YZ1131C4898

Sample Base: Drinking Water

Test purpose: Regular inspection

Sampling Date: 11/08/2024 09:45

Sample Received: 11/08/2024

Report Date: 11/19/2024

Report Number: C1134898-10

Sample Report Number		C1131108L				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								
		PASS						



Accreditation number by NERA : 041
(original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H11/ 12F water dispenser (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:50
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-11

Sample Report Number		C1131108M				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	11/08/2024 19:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
The END								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

Client Number: YZ1131C4898

Sample Base: Drinking Water

Plant: Golden Li H.R Consultant Co., Ltd

Test purpose: Regular inspection

IndustrialType: ---

Sampling Date: 11/08/2024 09:00

Sampling Site: Kaohsiung University dormitory No.338 H01/ 10F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Sample Received: 11/08/2024

Sampling Organization: Yuann International Technology Co., Ltd

Report Date: 11/19/2024

Sampling Method: ---

Report Number: C1134898-12

Sampling Code: ---

Sample Report Number		C1131108C				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H02/ 4F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:05
Sample Received: 11/08/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 11/19/2024
Report Number: C1134898-13

Sample Report Number		C1131108D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.336 H03/ 4F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:10
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-14

Sample Report Number		C1131108E				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd

Client Number: YZ1131C4898

Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

Sample Base: Drinking Water

Plant: Golden Li H.R Consultant Co., Ltd

Test purpose: Regular inspection

IndustrialType: ---

Sampling Date: 11/08/2024 09:15

Sampling Site: Kaohsiung University dormitory No.338 H04/ 1F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Sample Received: 11/08/2024

Sampling Organization: Yuann International Technology Co., Ltd

Report Date: 11/19/2024

Sampling Method: ---

Report Number: C1134898-15

Sampling Code: ---

Sample Report Number		C1131108F				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 , 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center

YUAN ZE UNIVERSITY


Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory No.338 H05/ 1F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:20
Sample Received: 11/08/2024

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 11/19/2024
Report Number: C1134898-16

Sample Report Number		C1131108G				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 , 0	NIEA E203.56B	100	
The END								
								

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H06/ Building B 7F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:25
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-17

Sample Report Number		C1131108H				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								
PASS								

Environmental Technology Research Center

YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H07 /Building A 7F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:30
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-18

Sample Report Number		C1131108I				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)

Client Number: YZ1131C4898
Sample Base: Drinking Water

Plant: Golden Li H.R Consultant Co., Ltd

Test purpose: Regular inspection

IndustrialType: ---

Sampling Date: 11/08/2024 09:35

Sampling Site: Kaohsiung University dormitory H08 /Building A 10F (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))

Sample Received: 11/08/2024

Sampling Organization: Yuann International Technology Co., Ltd

Report Date: 11/19/2024

Sampling Method: ---

Report Number: C1134898-19

Sampling Code: ---

Sample Report Number		C1131108J				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 , 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H09/ 1F water dispenser (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:40
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-20

Sample Report Number		C1131108K				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H10/ 12F water dispenser (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:45
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-21

Sample Report Number		C1131108L				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								

PASS

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Kaohsiung University dormitory H11/ 12F water dispenser (No.336.338, Daxue 7th St., Nanzi Dist., Kaohsiung City 811, Taiwan (R.O.C.))
Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Client Number: YZ1131C4898
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 11/08/2024 09:50
Sample Received: 11/08/2024
Report Date: 11/19/2024
Report Number: C1134898-22

Sample Report Number		C1131108M				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Total Bacterial Count	CFU/mL	<5	11/08/2024 19:00	TGE Agar	1/0 · 0	NIEA E203.56B	100	
The END								
			PASS					