



# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：御安淨水企業有限公司	委託編號：YZ1141C0044
委託者地址：桃園市平鎮區中豐路南勢二段 127 號	樣品基質：飲用水
受檢單位：錄興國際股份有限公司	檢測目的：定檢
行業別：自述業別	採樣時間：114年01月03日 10時00分
採樣地點：中壢中華二館 A06 飲水機 (桃園市中壢區)	收樣時間：114年01月03日
採樣單位：御安淨水企業有限公司	報告日期：114年01月09日
採樣方法：---	報告編號：C1140044-1
採樣行程代碼：---	

樣品報告編號		C1140103N				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年01月03日 12時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



Accreditation number by NERA : 041  
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center  
 YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden -Brother International Co., Ltd.  
**IndustrialType:** ---  
**Sampling Site:** Zhongli Zhonghua 2nd building A06 Drinking fountain

**Client Number:** YZ1141C0044  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 01/03/2025 10:00  
**Sample Received:** 01/03/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 01/09/2025  
**Report Number:** C1140044-1

Sample Report Number		C1140103N				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	01/03/2025 12:00	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
<b>The END</b>								
<b>PASS</b>								