



國環檢證字號：041(原環署環檢字第 041 號)

# 元智大學環科中心檢測實驗室

## 樣品檢驗報告

委託單位：	御安淨水企業有限公司	委託編號：	YZ1141C0241
委託者地址：	桃園市平鎮區中豐路南勢二段 127 號	樣品基質：	飲用水
受檢單位：	家興人力資源顧問股份有限公司	檢測目的：	定檢
行業別：	自述業別	採樣時間：	114年01月10日11時45分
採樣地點：	蘆竹大竹一館 1F 飲水機 (桃園市蘆竹區)	收樣時間：	114年01月10日
採樣單位：	御安淨水企業有限公司	報告日期：	114年01月17日
採樣方法：	---	報告編號：	C1140241-1
採樣行程代碼：	---		

樣品報告編號		C1140110D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培养基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年01月10日 20時00分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



Accreditation number by NERA : 041  
(original Accreditation number by EPA : 041)

Environmental Technology Research Center  
YUAN ZE UNIVERSITY  
Analysis Report

**Client:** Yuann International Technology Co., Ltd  
**Address:** No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)  
**Plant:** Golden Li H.R Consultant Co., Ltd  
**IndustrialType:** ---  
**Sampling Site:** Luzhu Dazhu Hall 1,1F Water Dispenser,

**Client Number:** YZ1141C0241  
**Sample Base:** Drinking Water  
**Test purpose:** Regular inspection  
**Sampling Date:** 01/10/2025 11:45  
**Sample Received:** 01/10/2025

**Sampling Organization:** Yuann International Technology Co., Ltd  
**Sampling Method:** ---  
**Sampling Code:** ---

**Report Date:** 01/17/2025  
**Report Number:** C1140241-1

Sample Report Number		C1140110D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	01/10/2025 20:00	LES Endo Agar	1/0 , 0	NIEA E230.55B	6	
<b>The END</b>								

PASS