



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：龜山山鶯一館 2F 飲水機
 (桃園市龜山區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1141C0331
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：114年01月14日16時00分
 收樣時間：114年01月15日
 報告日期：114年01月23日
 報告編號：C1140331-1

樣品報告編號		C1140115P				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年01月15日 10時30分	LES Endo Agar	1倍/0, 0	NIEA E230.55B	6	
以下空白								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：	御安淨水企業有限公司	委託編號：	YZ1141C0331
委託者地址：	桃園市平鎮區中豐路南勢二段 127 號	樣品基質：	飲用水
受檢單位：	家興人力資源顧問股份有限公司	檢測目的：	定檢
行業別：	自述業別	採樣時間：	114年01月14日16時05分
採樣地點：	龜山山鶯一館 3F 飲水機 (桃園市龜山區)	收樣時間：	114年01月15日
採樣單位：	御安淨水企業有限公司	報告日期：	114年01月23日
採樣方法：	---	報告編號：	C1140331-2
採樣行程代碼：	---		

樣品報告編號		C1140115Q				檢驗方法	環保署 飲用水 標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年01月15日 10時30分	LES Endo Agar	1倍/0,0	NIEA E230.55B	6	
以下空白								
								



元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
 委託者地址：桃園市平鎮區中豐路南勢二段 127 號
 受檢單位：家興人力資源顧問股份有限公司
 行業別：自述業別
 採樣地點：龜山山鶯一館 5F 飲水機
 (桃園市龜山區)
 採樣單位：御安淨水企業有限公司
 採樣方法：---
 採樣行程代碼：---

委託編號：YZ1141C0331
 樣品基質：飲用水
 檢測目的：定檢
 採樣時間：114年01月14日16時10分
 收樣時間：114年01月15日
 報告日期：114年01月23日
 報告編號：C1140331-3

樣品報告編號		C1140115R				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年01月15日 10時30分	LES Endo Agar	1 倍/0, 0	NIEA E230.55B	6	
以下空白								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Guishan Shanying Building 1, 2F water dispenser

Client Number: YZ1141C0331
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 01/14/2025 16:00
Sample Received: 01/15/2025

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 01/23/2025
Report Number: C1140331-1

Sample Report Number		C1140115P				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	01/15/2025 10:30	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								

PASS



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
 YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Guishan Shanying Building 1, 3F water dispenser

Client Number: YZ1141C0331
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 01/14/2025 16:05
Sample Received: 01/15/2025

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 01/23/2025
Report Number: C1140331-2

Sample Report Number		C1140115Q				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	01/15/2025 10:30	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								
PASS								



Accreditation number by NERA : 041
 (original Accreditation number by EPA : 041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY

Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Golden Li H.R Consultant Co., Ltd
IndustrialType: ---
Sampling Site: Guishan Shanying Building 1, 5F water dispenser

Client Number: YZ1141C0331
Sample Base: Drinking Water
Test purpose: Regular inspection
Sampling Date: 01/14/2025 16:10
Sample Received: 01/15/2025

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 01/23/2025
Report Number: C1140331-3

Sample Report Number		C1140115R				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	01/15/2025 10:30	LES Endo Agar	1/0 · 0	NIEA E230.55B	6	
The END								

PASS