國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司
委託者地址：桃園市平鎮區中豐路南勢二段 127 號
受檢單位：宏普人力資源股份有限公司
行業別：自述業別
採樣地點：新竹中華一館 2F/A3 飲水機 (新竹市北區)
採樣單位：御安淨水企業有限公司
採樣方法：---
採樣行程代碼：---

委託編號：YZ1141C0992
樣品基質：飲用水
檢測目的：定檢
採樣時間：114年03月06日14時30分
收樣時間：114年03月07日
報告日期：114年03月19日
報告編號：C1140992-1

樣品報告編號		C1140307C				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年03月07日 12時00分	LES Endo Agar	1 倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號 聯絡人：陳秀雲
電話：(03)455-8017 FAX：(03)463-5887

國環檢證字號：041(原環署環檢字第 041 號)

元智大學環科中心檢測實驗室

樣品檢驗報告

委託單位：御安淨水企業有限公司　　委託編號：YZ1141C0992
委託者地址：桃園市平鎮區中豐路南勢二段 127 號　　樣品基質：飲用水
受檢單位：宏普人力資源股份有限公司　　檢測目的：定檢
行業別：自述業別　　採樣時間：114年03月06日14時35分
採樣地點：新竹中華一館 8F/A8 飲水機 (新竹市北區)　　收樣時間：114年03月07日
採樣單位：御安淨水企業有限公司　　報告日期：114年03月19日
採樣方法：---　　報告編號：C1140992-2
採樣行程代碼：---

樣品報告編號		C1140307D				檢驗方法	環保署飲用水標準值	備註欄
原樣名稱或編號		飲用水						
檢測項目	單位	檢測值	開始培養時間	培養基名稱	原始數據			
大腸桿菌群	CFU/100 mL	<1	114年03月07日 12時00分	LES Endo Agar	1倍/0，0	NIEA E230.55B	6	
以下空白								

PASS

檢驗室地址：桃園市中壢區遠東路 128 號　聯絡人：陳秀雲
電話：(03)455-8017　FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Summit Manpower Agency Co,Ltd
IndustrialType: ---
Sampling Site: Hsinchu Zhonghua Building 1, 2F/A3 water dispenser

Client Number: YZ1141C0992
Sample Base: Drinking Water
Test purpose: **Regular inspection**
Sampling Date: 03/06/2025 14:30
Sample Received: 03/07/2025

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2025
Report Number: C1140992-1

Sample Report Number		C1140307C				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/07/2025 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887

Accreditation number by NERA：041
(original Accreditation number by EPA：041)

Environmental Technology Research Center
YUAN ZE UNIVERSITY
Analysis Report

Client: Yuann International Technology Co., Ltd
Address: No.127, Nanshi Sec. 2, Zhongfeng Rd., Pingzhen City, Taoyuan County, Taiwan (R.O.C.)
Plant: Summit Manpower Agency Co,Ltd
IndustrialType: ---
Sampling Site: Hsinchu Zhonghua Building 1, 8F/A8 water dispenser

Client Number: YZ1141C0992
Sample Base: Drinking Water
Test purpose: **Regular inspection**
Sampling Date: 03/06/2025 14:35
Sample Received: 03/07/2025

Sampling Organization: Yuann International Technology Co., Ltd
Sampling Method: ---
Sampling Code: ---

Report Date: 03/19/2025
Report Number: C1140992-2

Sample Report Number		C1140307D				Analytical Method	Drinking water standard of EPA	Remarks
Sample Name(Number)		Drinking Water						
Analyzed Item	Unit	Analytical Value	Start Time of Incubating	Medium	Original Data			
Coliform Group	CFU/100 mL	<1	03/07/2025 12:00	LES Endo Agar	1/0，0	NIEA E230.55B	6	
The END								

PASS

Address: #128, Yuan-Tung Road, Chung-Li, Tao-Yuan, Taiwan 320, R.O.C. Contact: Hsiu Yun Chen
TEL：(03)455-8017 FAX：(03)463-5887